

**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM
LISTING SERVICE**

LISTING No. 7165-0067:035

Page 1 of 2

CATEGORY: Control Unit (Non High Rise)

LISTEE: Siemens Building Technologies Inc., *Fire Safety Div., 8 Fernwood Rd, Florham Park NJ 07932
Contact: Peter Pawchak (973) 593-2662 Fax (973) 593-6652

DESIGN: Model "SYSTEM 3" fire alarm control unit. Local, auxiliary, remote station (protected premises) or proprietary service. Model CP-35 and ZU-35 Series initiating circuits are power limited. Refer to listee's data sheet and control unit's installation instructions for additional detailed product description and operational considerations. System components:

CP-30, -31, -35	Control Module
ZA-30 through -33, ZB-35, ZC-30, -31, ZH-30, -GD	Initiating Module
ZN-30 through -34, ZN-31U, -34US, ZU-35, -35DS	Initiating Module
ZU-35TS, MC-30, ZN-34U2	Initiating Module
AE-30, -30U, -31, AA-30, -30U	Alarm Module
SR-30, -32, -33, -35	Alarm Module
BC-30, -35, BE-35, BM-30, -31, TC-30U, DC-35S, PF-30	Power Supply Module
PS-3, -30, -31, -34, -35, -35S, DM-30R, MM-3RS	Power Supply Module
MM-30, -31, -32, -35	Power Supply Module
EA-30 through -35	Enclosure
PL-35	Power Limited Module
BI-35	Power Supply Interface
LP-30, MT-30	Remote Signaling Panel
SR-30, -31, AC-30, -30U, TS-30, HS-30, HC-30U	Control Module
RM-30U, -30RU, DS-30, -31, RC-30, SA-30, AW-1, -2	Control Module
SM-30, -31, TL-30U, AD-30S, HC-35, CT-35, PM-31, -32	Control Module
QS-30	Linear Detection Cable
CSI-35	Central Control Interface

RATING: 120-240 VAC

INSTALLATION: In accordance with listee's printed installation instructions, NFPA 72, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name or Cerberus Pyrotronics, model number, rating and UL label.

APPROVAL:

Listed as fire alarm control unit for use with separately listed compatible initiating and indicating devices.

This control unit does not generate a temporal pattern signal. If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition is required, the control unit must be used with appliances that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.

*Rev. 10-26-2002 BH



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **OCTOBER 26, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND**, Senior Deputy
Program Manager